



Empowered lives. Resilient nations.

100 Percent Renewable Electricity in Sri Lanka by 2050

A UNDP/ADB study Manila, 5 June 2017

Dr. Milou Beerepoot, Regional Technical Advisor, UNDP








- Background to the study
- A scenario for 100% RE in Sri Lanka by 2050
 - Assumptions/conditions
 - Projections
 - Balancing and storage requirements
 - Fuel cost savings and investment needs
- De-risking to lower costs of finance
- Conclusions

Background to this study



- By 2050, Sri Lanka's electricity demand is likely to increase five folds to ~70,000 GWh (from ~14,000 GWh in 2016)
- As part of Sri Lanka Nationally Determined Contributions (NDC) submitted to UNFCCC: 50% RE by 2030
- As part of Sri Lanka's participation in Climate Vulnerable Forum: 100% RE by 2050




A 100% RE by 2050 scenario; assumptions



- No energy efficiency, demand side management or load shifting
- Cap on solar of 30% by 2050
- Cap on wind of 50% by 2050
- Two sub-critical coal units (300 MW) added in 2024 and 2027 as planned
- No coal plant commissioned in Tricomalee (1100 MW)

Sri Lanka 100% RE 2050: a scenario




- Solar and wind will dominate the power generation in 2050
- Coal will first increase (2024 & 2027) but phase out after 2040



2030 - Typical daily demand-supply scenario






- By 2030, Sri Lanka will need to increase its storage capacity to meet a peak demand deficit of 900 MW
- By 2030, the cost of battery storage is expected to drop significantly, which may trigger a shift in focus to battery storage


2050 - Typical daily demand-supply scenario





- By 2050, the supply curve will further skew to the middle, storage will become an imperative necessity
- The total storage requirement is expected to be ~15,000 MWh


Investment Need for 100% RE by 2050




- Total costs, not additional costs compared to a baseline scenario (baseline includes increased electricity demand and Trans.&Distr.)
- Highest costs in last decade: cost prediction long term faced with high level of uncertainty



Fuel cost savings



 Comparing a scenario of continuous coal based power generation with the 100% RE scenario leads to cumulative fuel cost savings of 18,500 Million USD by 2050, which can cover substantial part of RE investment need




- Several risks for institutional investors are adding up to costs of finance
- "De-risking" interventions can reduce risks and lower costs of finance

UNDP's de-risking approach




Empowered lives Resilient nations



- De-risking: (public) instrument packages that
 - reduce risk,
 - transfer risk or
 - compensate for risk

Cheapest approach

UNDP's de-risking approach



- De-risking in Sri Lanka can consist of:
 - adjusting business model of CEB (remove cross-subsidies)/ power market reform
 - introduce a stable and RE focused policy regime
 - a simpler and comprehensive framework for land acquisition
 - payment security systems to mitigate off-taker risk of PPA's
 - (governmental) currency hedging facility
 - infrastructure debt funds
 - partial credit guarantee for IPPs





- Sri Lanka's commitment to 100% RE in 2050 is commendable and possible
- **Cost reductions** of **solar** energy as well as **storage** solutions will add to feasibility of 100% RE in 2050
- Additional efforts in energy efficiency and demand side management will further enhance feasibility of 100% RE
- Costs of investments will need further study, de-risking approaches can reduce costs of finance
- De-risking approaches can consist of:
 - policy de-risking (cheapest approach), e.g. adjusting CEB's business model, power market reform, stable RE policy regime and facilitated land acquisition
 - financial de-risking, e.g. payment security systems, (governmental) currency hedging facility, infrastructure debt funds, partial credit guarantee for IPPs



Empowered lives Resilient nations

Thank you! Email: milou.beerepoot@undp.org

The 2050, 100 percent Renewable Energy Electric

<u>Demand</u>

2016-34: Demand has been kept the same as estimated by the CEB and reported in "Long Term Generation *diversed lives.* Expansion Plan 2015-34 (LTGEP)".

2035-50: Electricity demand for 2035-50 is estimated at a CAGR of **4.8 percent**, extrapolated from the 2020-34 CAGR present in the LTGEP.

Plant Load Factor (on average)

| Generation Source | PLF (%) | Sources | | | |
|-------------------|---------|------------------------------------|--|--|--|
| Gas Turbine | 20 | SL'a parformance in 2015 | | | |
| Oil Based | 20 | SL's performance in 2015. | | | |
| Combine Cycle | 50 | Assumed. | | | |
| Coal | 60 | SL's performance in 2014 and 2015. | | | |
| Large Hydro | 40 | - Historical values of SL. | | | |
| Small Hydro | 39 | | | | |
| Wind | 30 | Standard off-shore wind PLF. | | | |
| Biomass | 70 | CEB assumption. | | | |
| Solar | 17 | Standard solar PLF. | | | |

Fossil fuel capacity addition

Two sub-critical coal units of 300 MW capacity slated going to be commissioned in 2024 and 2027 respectively (as per the LTGEP) have been retained to be used as base load instead of RE during the initial years of the strategy.

As the strategy proceeds and more RE gets added contribution from these coal units decrease.

The 2050, 100 percent Renewable Energy Electric

Mix of Solar and Wind

Solar: 30% of total demand

Wind: 50% of total demand

Given the relative immaturity of the solar industry in Sri Lanka, a very high concentration of solar energy is likely to pose balancing issues for the grid and until storage facilities have evolved to become commercially viable in Sri Lanka, demand that cannot be met by solar will be primarily catered to through wind.

Other energy sources

Capacity addition of large hydro, small hydro and biomass has been continued as per the capacity additions provided in the long-term generation plan.

Economic savings from fuel cost avoidance

Imported fuel cost: 1550 US cents /GCal

Coal plant Station Heat Rate (SHR): 2400 kCal/kWh



Demand Management and Balancing Requirements

Load Profile

Sri Lanka's future load curve profile has been assumed to remain the same as in 2015.

Availability Factors for various sources of electricity

Solar and Wind: The most conservative supply profile in the southern states of India has been considered

Hydro: Minimum availability of 40 percent throughout the day has been assumed

Coal and Combine Cycle Plants: Availability factor of 90 percent has been assumed

Profiles for Wind, Solar and Hydro are assumed based on closest available information due to data paucity in Sri Lanka and actual generation may be different from what has been assumed depending on seasonal variability

Auxiliary Power Consumption (APC) Percentages

APC figures are as per industry standard



Resilient nations.

Investment Requirements

Capital Costs

Solar: Fraunhofer ISE- Current and future cost of photovoltaics by Agora Energiewende

Wind: India benchmark, IEA Wind Road map

Others: Industry interactions, India benchmark

| | Capital cost (USD/kW) | | | | | | | | |
|------|-----------------------|-------|------|------|--------|-------------|-------------|---------|--|
| Year | Solar (Euro/kW) | Solar | Wind | Coal | CC/Gas | Large Hydro | Small Hydro | Biomass | |
| 2016 | 900 | 1000 | 1500 | 1300 | 1200 | 1700 | 2000 | 1600 | |
| 2017 | 900 | 1000 | 1500 | 1300 | 1200 | 1700 | 2000 | 1600 | |
| 2018 | 862 | 957 | 1500 | 1300 | 1200 | 1700 | 2000 | 1600 | |
| 2019 | 823 | 914 | 1500 | 1300 | 1200 | 1700 | 2000 | 1600 | |
| 2020 | 823 | 914 | 1500 | 1300 | 1200 | 1700 | 2000 | 1600 | |
| 2021 | 823 | 914 | 1500 | 1300 | 1200 | 1700 | 2000 | 1600 | |
| 2022 | 823 | 914 | 1500 | 1300 | 1200 | 1700 | 2000 | 1600 | |
| 2023 | 774 | 859 | 1500 | 1300 | 1200 | 1700 | 2000 | 1600 | |
| 2024 | 724 | 804 | 1500 | 1300 | 1200 | 1700 | 2000 | 1600 | |
| 2025 | 724 | 804 | 1500 | 1300 | 1200 | 1700 | 2000 | 1600 | |
| 2026 | 724 | 804 | 1500 | 1300 | 1200 | 1700 | 2000 | 1600 | |
| 2027 | 724 | 804 | 1500 | 1300 | 1200 | 1700 | 2000 | 1600 | |
| 2028 | 688 | 764 | 1500 | 1300 | 1200 | 1700 | 2000 | 1600 | |
| 2029 | 651 | 723 | 1500 | 1300 | 1200 | 1700 | 2000 | 1600 | |
| 2030 | 651 | 723 | 1500 | 1300 | 1200 | 1700 | 2000 | 1600 | |
| 2031 | 651 | 723 | 1500 | 1400 | 1300 | 1700 | 2000 | 1600 | |
| 2032 | 651 | 723 | 1500 | 1400 | 1300 | 1700 | 2000 | 1600 | |
| 2033 | 617 | 686 | 1500 | 1400 | 1300 | 1700 | 2000 | 1600 | |
| 2034 | 583 | 648 | 1500 | 1400 | 1300 | 1700 | 2000 | 1600 | |
| 2035 | 583 | 648 | 1500 | 1400 | 1300 | 1700 | 2000 | 1600 | |
| 2036 | 583 | 648 | 1500 | 1400 | 1300 | 1700 | 2000 | 1600 | |
| 2037 | 583 | 648 | 1500 | 1400 | 1300 | 1700 | 2000 | 1600 | |
| 2038 | 555 | 616 | 1500 | 1400 | 1300 | 1700 | 2000 | 1600 | |
| 2039 | 526 | 584 | 1500 | 1400 | 1300 | 1700 | 2000 | 1600 | |
| 2040 | 526 | 584 | 1500 | 1400 | 1300 | 1700 | 2000 | 1600 | |
| 2041 | 526 | 584 | 1500 | 1400 | 1300 | 1700 | 2000 | 1600 | |
| 2042 | 526 | 584 | 1500 | 1400 | 1300 | 1700 | 2000 | 1600 | |
| 2043 | 503 | 558 | 1500 | 1400 | 1300 | 1700 | 2000 | 1600 | |
| 2044 | 479 | 532 | 1500 | 1400 | 1300 | 1700 | 2000 | 1600 | |
| 2045 | 479 | 532 | 1500 | 1400 | 1300 | 1700 | 2000 | 1600 | |
| 2046 | 479 | 532 | 1500 | 1400 | 1300 | 1700 | 2000 | 1600 | |
| 2047 | 479 | 532 | 1500 | 1400 | 1300 | 1700 | 2000 | 1600 | |
| 2048 | 458 | 508 | 1500 | 1400 | 1300 | 1700 | 2000 | 1600 | |
| 2049 | 436 | 484 | 1500 | 1400 | 1300 | 1700 | 2000 | 1600 | |
| 2050 | 436 | 484 | 1500 | 1400 | 1300 | 1700 | 2000 | 1600 | |



Investment Requirements

Transmission Costs

In Sri Lanka, the average incremental cost estimated for transmission infrastructure development is LKR190,000/kW Resilient nations.

Battery Storage Costs

| Year | Investment cost (USD/kWh) |
|------|---------------------------|
| 2030 | 140 |
| 2040 | 105 |
| 2050 | 105 |

U.S. Department of Energy, EV Everywhere Grand Challenge Blueprint.

Available from: https://energy.gov/eere/electricvehicles/about-electric-vehicles.

Pump Storage Costs

| Year | Investment cost (USD/kW) |
|------|--------------------------|
| 2030 | 1700 |
| 2040 | 1700 |
| 2050 | 1700 |

